

# DoP DECLARATION of PERFORMANCE

N° VE0510CPR20130701 (Conformity EU 305/2011)

1. Unique identification code of the product type:

**VMIC404**  
**VMIC422**  
**VMIC602**  
**VMCZ100**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under article 11(4) of the CPR:

**VMIC404 Analogue 4In/4Out-Rel - Input/output device and short circuit isolator**  
**VMIC422 Analogue 4In/2Out-Sup/2Out-Rel - Input/output device and short circuit isolator**  
**VMIC602 Analogue 6In/2Out-Rel - Input/output device and short circuit isolator**  
**VMCZ100 Conventional Zone Module - Input/output device and short circuit isolator**

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

**For use in compatible fire detection and alarm system**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5):

**ARGUS SECURITY Srl**  
**Via del Canneto 14**  
**Valle delle Noghère**  
**34015 Muggia - Trieste – Italy**  
**info@argussecurity.it**     [www.argussecurity.it](http://www.argussecurity.it)

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in article 12(2):

**N/A**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

**System 1**



7. In case of the declaration of performance concerning a construction product covered by harmonized standard:

**EN 54-17: 2005**

**EN 54-18: 2005**

**IMQ S.p.A. , N.B. No. 0051, performed the necessary initial inspection of the manufacturing plant and the factory production control together with ongoing continuous surveillance and issued the certificate confirming constancy of the conformity of the factory production control**

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

**N/A**

9. Declared performance:

<b>ESSENTIAL CHARACTERISTICS</b>	<b>CLOSE APPLICABLE</b>	<b>PERFORMANCE</b>	<b>HARMONISED STANDARD</b>
Performance parameters under fire conditions	5.2	PASS	EN 54-17:2005
Operational reliability	4	PASS	
Durability of operational reliability, temperature resistance	5.4, 5.5	PASS	
Durability of operational reliability, vibration resistance	5.9 to 5.12	PASS	
Durability of operational reliability, humidity resistance	5.6, 5.7	PASS	
Durability of operational reliability, corrosion resistance	5.8	PASS	
Durability of operational reliability, electrical stability	5.3, 5.13	PASS	

<b>ESSENTIAL CHARACTERISTICS</b>	<b>CLOSE APPLICABLE</b>	<b>PERFORMANCE</b>	<b>HARMONISED STANDARD</b>
Response delay (response time)	5.2	PASS	EN 54-18:2005
Performance under fire conditions	5.1.4		
Operational reliability	5.1.4	PASS	
Durability of operational reliability, temperature resistance	5.3, 5.4	PASS	
Durability of operational reliability, vibration resistance	5.8 to 5.11	PASS	
Durability of operational reliability, humidity resistance	5.5, 5.6	PASS	
Durability of operational reliability, corrosion resistance	5.7	PASS	
Durability of operational reliability, electrical stability	5.2, 5.12	PASS	



10. The performance of the products identified in points 1 and 2 are in conformity with the declared performance in the point 9. This declaration is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Ing. V.Nesta – Managing Director – Argus Security Srl, Trieste - ITALY

Trieste, 01 July 2013

**ARGUS SECURITY**  
S.r.l.



**Vincenzo Nesta**  
Managing Director