

**EC Declaration of Conformity**  
*In accordance with EU Constructions Products Directive 89/106/EEC*



0086-CPD-533485

We: **Argus Security S.r.l**  
**Via Archimede, 42**  
**20041 Agrate B.za (Milano) – Italy**

The primary Importer/Distributor within the EU hereby declares that the product:

**VMI100** **Vega Addressable Supervised Input Module**  
**VMMI100** **Vega Addressable Supervised Input Mini Module**

for use in fire detection and alarm systems

has been third party tested and certified by: **BSI Product Services**, Maylands Avenue  
Hemel Hempstead, HP2 4SQ, UK  
Notified Body: 0086


and hence complies with the essential requirements of the EN54-18:2005 Annexe ZA – Fire detection and fire alarm systems – Input / Output Devices, when used for its intended purpose in accordance with issued specifications and installation instructions.

Technical Documentation maintained by: **ARGUS SECURITY S.r.l**

Place and date: **Agrate Brianza, Milano, Italy** **21 April 2008**

Person in-charge: **Mr. Vincenzo Nesta**  
**Director**

Signature:

  
**ARGUS SECURITY S.r.l.**  
Consigliere Delegato  
(ing. V. Nesta)

Date: 21 April 2008