

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

LUMINAIRES FOR EMERGENCY LIGHTING (wall/ceiling)

INIM ELECTRONICS S.r.I.
VIA DEI LAVORATORI 10
FRAZ. CENTOBUCHI

63076 MONTEPRANDONE AP

Italy

INIM ELECTRONICS S.r.I. VIA DEI LAVORATORI 10 FRAZ. CENTOBUCHI

63076 MONTEPRANDONE AP

Italy

Additional information on page 2

LIXIT S.r.I.

VIA DELL'INDUSTRIA 16 FRAZ. PAGLIARE DEL TRONTO 63078 SPINETOLI AP

Italy

LED 230V - cl. II - IP40 - risk group: RG0 (see Additional Sheet and Test

Report)

inim

inim ELECTRONICS

Series HARPER320 and HARPER330 (see Additional Sheet and Test Report)

Additional information on page 2

IEC 60598-1:2014, IEC 60598-1:2014/AMD1:2017, IEC 60598-2-22:2014, IEC 60598-2-22:2014/AMD1:2017, IEC TR 62778:2014

National differences:

EU Group Differences

Al20-0055618-01, Al20-0055618-05, Al20-0055618-06

This CB Test Certificate is issued by the National Certification Body

IMQ S.p.A.

Via Quintiliano 43, IT-20138 Milano, Italy



Date: 2020-12-01 Signature: Giorgio Belussi



DESCRIPTION OF LUMINAIRES SERIES HARPER320 and HARPER330

Type Ref.	Rated input power	Nr of LED	Duration	Battery type LiFePO4	Туре	Rated lumen output emergency/maintained operation	IP
SELF-TEST							
HP320AA000340	3,5 W	10	3h	221/ 15 / h	5,2 V - 1,5 Ah Maintained 5,2 V - 3,3 Ah	20 lm	
HP330AA000140	4,8 W	20	1h	3,2 V - 1,3 AII		30 lm	IP40
HP330AA000340	4,8 W	20	3h	3,2 V - 3,3 Ah		30 IIII	
BUS-SUPERVISED							
HP320BA000340	3,5 W	10	3h	3,2 V - 1,5 Ah Maintai 3,2 V - 3,3 Ah	Maintained	20 lm	IP40
HP330BA000140	4,8 W	20	1h			30 lm	
HP330BA000340	4,8 W	20	3h				
CENTRAL BATTERY							
HP320LA000040	1,7 W	10			Central	20 lm	IP40
HP330LA000040	3,1 W	20			Battery	30 lm	

Mod. 3272/0 page 1 of 1