



By Appointment to  
Her Majesty The Queen  
Manufacturers of Fire Detection & Alarm Products  
Apollo Fire Detectors Limited  
Hampshire



**Construction Products Regulation:  
EU (No) 305/2011**

This Declaration has been drawn-up in accordance with Commission Delegated Regulation (EU) No. 574/2014 which amends Annex III of Regulation (EU) No 305/2011.

**DECLARATION OF PERFORMANCE**

**No. 2531-CPR-CSP11013**

**1. Unique identification code of the product-type:**

**Model number and Description:**

55100-908 XP95 Analogue Addressable Manual Call Point with Short Circuit Isolator  
55100-908LIM XP95 Analogue Addressable Manual Call Point with Short Circuit Isolator  
55100-908SIL XP95 Analogue Addressable Manual Call Point with Short Circuit Isolator

**Approved Accessories:**

Surface Mounting Box

**Harmonised Product Type(s):**

Manual Call Points  
Short Circuit Isolators

**2. Intended use/es:**

Fire detection and fire alarm systems

**3. Manufacturer:**

Apollo Fire Detectors Ltd,  
36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

**4. Authorised representative:**

Apollo Gesellschaft für Meldetechnologie mbH  
Am Anger 31  
33332 Gütersloh  
Deutschland

Note that Apollo UK has, by issue of written mandate, authorised the above entity to act as Importer for these products and carry out the duties required of an Importer within the EU.

**5. System of AVCP**

System 1

**6a. Harmonised Standard(s)**

EN 54-11:2001 + A1:2005  
EN 54-17:2005

A HALMA COMPANY



**Apollo Fire Detectors Limited**

36 Brookside Road, Havant, Hampshire, PO9 1JR, UK  
t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk

[www.apollo-fire.co.uk](http://www.apollo-fire.co.uk)

Apollo Fire Detectors Ltd. Registered in England No. 1483208  
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54

6b. **Notified Body:**

DBI Certification A/S (Notified Body 2531)

7. **Declared performance**

<b>Essential Characteristics</b>	<b>Standard EN54-11:2001 + A1:2005</b>	<b>Performance</b>
Nominal activation conditions/Sensitivity and Performance under fire conditions	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	Pass
Operational reliability	4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	Pass
Durability of operational reliability: temperature resistance	5.7, 5.8*, 5.9	Pass
Durability of operational reliability: vibration resistance	5.14 to 5.17	Pass
Durability of operational reliability: humidity resistance	5.10, 5.11*, 5.12, 5.19*	Pass
Durability of operational reliability: corrosion resistance	5.11, 5.13	Pass
Durability of operational reliability: electrical resistance	5.6, 5.18†	Pass
5.8* Outdoor Devices only 5.11*, 5.19* Outdoor Devices only 5.18† Devices with active electronic components only		

<b>Essential Characteristics</b>	<b>Standard EN54-17:2005</b>	<b>Performance</b>
Performance under fire conditions	5.2 <sup>(1)</sup>	Pass
Operational reliability	4	Pass
Durability of operational reliability: temperature resistance	5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	5.8	Pass
Durability of operational reliability: electrical stability	5.3, 5.13	Pass
1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices		



The performance of the product identified above is in the conformity with the set of declared performance/s.  
This declaration of performance is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above.

**8. Online Display Location**

This document can be viewed online at [www.apollo-fire.co.uk](http://www.apollo-fire.co.uk)

Signed for and on behalf of Apollo Fire Detectors Limited by:



Mr. Karl Westhead  
Technical Director

Place and Date of Issue: Havant - 29 March 2021

(v5)

