

CERTIFICATE OF CONSTANCY OF PERFORMANCE 0051–CPR–2764

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation, or CPR), this Certificate applies to the construction product

Product:

HEAT DETECTOR USING RADIO LINKS

Models: WD200; WD200B

Trademark: INIM

Other information: See ANNEX

Produced by: INIM ELECTRONICS S.r.I. Via Dei Lavoratori 10 – Frazione Centobuchi 63076 Monteprandone (AP), Italy

> in the manufacturing plant: **PI.X0000H**

This Certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-5:2017 + A1:2018 EN 54-25:2008 + AC:2012

Under system 1 are applied and that the product fulfills all the prescribed requirements set out above

ISSUED ON 30/12/2022

Ο

Revision

B.U. Product Conformity Assessment CPR Technical Director

(ENG. VALBERTO BAGGIO)

This certificate was first issued on 30/12/2022 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonized standard, used to assess the performance of the declared characteristics, do not change, and the products, and the manufacturing conditions in the plant are not modified significantly.

This Certificate was issued by IMQ S.p.A., a Notified Body according to Regulation (EU) No. 305/2011. IMQ S.p.A. Identification Number is: **0051**.This certificate is subjected to the Regulation of Assessment and Verification of Constancy of Performance of the Construction Products as Notified Body, according to Regulation (EU) no. 305/2011 and Legislative Decree n.106/ 2017 (REG. ON / CPR)



PRD N° 005 B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC Signatory of EA, IAF and ILAC Mutual Recognition Agreements



ANNEX 0051-CPR-2764

Model WD200

Configuration:

The heat detector model WD200 consists of a white plastic enclosure (dimensions: 110 (d) \times 65 (h) mm) with IP40 degree of protection, containing:

- No. 1 Main board (PCB code B40-LB100-0004);
- No. 2 Battery allocable (CR123A Lithium, 3 V 1.25Ah).

Technical Characteristics

- Operating frequency band: 868 MHz;
- Hardware identification of the microcontroller (U4) used on the main board: STMicroelectronics, STM32L051R8;
- Firmware identification of the microcontroller (U4) used on the main board: 0_{1}

Model WD200B

Configuration:

The heat detector model WD200B is identical to the model WD200 but with black enclosure.

Mod. 0727CPR-ENG/3

This Certificate was issued by IMQ S.p.A., a Notified Body according to Regulation (EU) No. 305/2011. IMQ S.p.A. Identification Number is: **0051**.This certificate is subjected to the Regulation of Assessment and Verification of Constancy of Performance of the Construction Products as Notified Body, according to Regulation (EU) no. 305/2011 and Legislative Decree n.106/ 2017 (REG. ON / CPR)



PRD N° 005 B

Pagina 2 di 2

Aembro degli Accordi di Mutuo Sconoscimento EA, IAF e ILAC Ignatory of EA, IAF and ILAC Autual Recognition Agreements