

UL-EU CERTIFICATE

Certificate No. UL-EU-01111-CPR
Page 1/3
Date of Issue 2019-05-30
Date of Re-Issue 2023-07-20

Certificate Holder Inim Electronics s.r.l,
Via Dei Lavoratori 10
Frazione Centobuchi
63076 Montepandone (Ap)
Italy

Manufacturer As per certificate holder

Certified Product Type Smoke detectors — Point detectors using scattered light, transmitted light or ionization for fire detection and fire alarm systems for buildings.

Heat detectors — Point detectors for fire detection and fire alarm systems for buildings.

Short-circuit isolator for fire detection and fire alarm systems for buildings

Product Trade Name	ED100	Analog, Addressable Optical Smoke Detector with Short Circuit Isolator
	ED200	Analog, Addressable Heat Detector with Short Circuit Isolator
	ED300	Analog, Addressable Multicriteria Detector with Short Circuit Isolator
	EB0010	Detector Mounting Base



Authorized Certification Decision Maker

Richard Bristow

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



UL-EU CERTIFICATE

Certificate No. UL-EU-01111-CPR
Page 2/3
Date of Issue 2019-05-30
Date of Re-Issue 2023-07-20

Trademark

The logo for 'inim' is displayed in a blue, lowercase, sans-serif font. The letters 'i' and 'n' have small blue dots above them, suggesting a stylized or digital theme.

Rating/Classification

19 - 30 V DC
ED200 / ED300 - Heat Detection Class A1R and Class B
*Note: Class A2S and Class BR are **not** certified.*

Harmonised Technical Specifications

EN54-5:2017 + A1:2018
EN54-7:2018
EN54-17:2005 + AC:2007

Supporting Documentation

S36176-D01-EUROPEAN DIRECTIVE-ORIGINAL

Additional information

Expiry date

2029-05-29



Appendix UL-EU Certificate

Certification Mark	UL-EU mark
Certificate No.	UL-EU-01111-CPR
Page	3/3
Date of Issue	2019-05-30
Date of Re-Issue	2023-07-20

The UL-EU Mark, as displayed below, shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number are also required on that same label or nameplate. If cast, stamped or molded, the Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at www.ul.com.

